

## Appendix A - Analytical Results

Table A-14i: Electrical Transformers PCB

Location	Sample Name	Sample Type	PCB-1016 (AROCHLOR 1016)	PCB-1221 (AROCHLOR 1221)	PCB-1232 (AROCHLOR 1232)	PCB-1242 (AROCHLOR 1242)	PCB-1248 (AROCHLOR 1248)	PCB-1254 (AROCHLOR 1254)	PCB-1260 (AROCHLOR 1260)
			ug/kg	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg	ug/kg
PA-TR1	PA-TR1-1	N	< 6.2	< 10	< 19	< 9.9	< 13	< 14	< 6.7
PA-TR2	PA-TR2-1	N	< 6.2	< 10	< 19	< 9.9	< 13	< 14	< 6.7
PA-TR3	PA-TR3-1	N	< 6.2	< 11	< 19	< 9.9	< 14	42 J	< 6.8
PA-TR4	PA-TR4-1	N	< 6.2	< 11	< 19	< 9.9	< 14	< 14	< 6.8
PA-TR5	PA-TR5-1	N	< 6.2	< 10	< 19	< 9.9	< 13	< 14	< 6.7

Minimum	<6.2	<10	<19	<9.9	<13	<14	<6.7
Average <sup>(1)</sup>	3.1	5.2	9.5	5.0	6.7	14.0	3.4
Maximum	<6.2	<11	<19	<9.9	<14	42	<6.8
Total Analyzed (incl. dup)	5	5	5	5	5	5	5
Number Detected	0	0	0	0	0	1	0
Freq. of Detection	0%	0%	0%	0%	0%	20%	0%
Number Estimated	0	0	0	0	0	1	0
Frequency Estimated	0%	0%	0%	0%	0%	20%	0%
Number Rejected	0	0	0	0	0	0	0
Frequency Rejected	0%	0%	0%	0%	0%	0%	0%
Screening PRG <sup>(2)</sup>	<b>37,000</b>	<b>37,000</b>	<b>37,000</b>	<b>37,000</b>	<b>37,000</b>	<b>37,000</b>	<b>37,000</b>
Number >PRG	0	0	0	0	0	0	0
Frequency >PRG	0%	0%	0%	0%	0%	0%	0%

NA - Not applicable, no screening level established.

N - Normal sample.

FD - Field duplicate.

J - Estimated result.

R - Rejected result. Laboratory reported result was rejected and not used for any purpose.

<sup>(1)</sup> Mathematical average. Non-detected results are averaged as one half the value of the minimum detection limit.<sup>(2)</sup> Screening PRG based on EPA Region IX Industrial Worker Preliminary Remediation Goal